

ADDENDUM #4

March 5, 2021

PROJECT: **STERLING NATURE CENTER
NEW VISITOR'S CENTER AND SITE IMPROVEMENTS PROJECT
15380 JENSVOLD ROAD, STERLING NY
BEARDSLEY PROJECT NUMBER – 19004.001**

ARCHITECT: **BEARDSLEY ARCHITECTS + ENGINEERS
64 South Street
Auburn, NY 13021**

OWNER: **COUNTY OF CAYUGA
160 Genesee Street
Auburn, NY 13021**

The following **revisions and clarifications** to the SPECIFICATIONS and DRAWINGS shall be considered to be a part of the Contract Documents herewith:

A.) REVISIONS

DRAWINGS

- ITEM No. 1** **DRAWING C-509: TIMBER GUIDERAIL DETAIL**
Add the following as note #5 to detail 8/C-509
"5. Wood components shall be pressure treated #2 Southern Yellow Pine or equal, rated for ground contact. "
- ITEM No. 2** **DRAWING S-401: GLULAM FRAME CONNECTIONS**
Drawing S-401 and other locations depict the use of bolted steel gusset plates for glulam truss member connections. Alternate connection methods such as traditional mortise and tenon joinery may be acceptable provided structural design criteria are met. The documentation and submittal requirements outlined in the specifications remain unchanged.

NOTE: BID DUE DATE TO REMAIN AT 12 NOON ON TUESDAY MARCH 9, 2021 PER ADDENDUM #1.

END OF ADDENDUM #4